

APPENDIX A
Additional Limits for Certain Pollutants

It shall be unlawful for any industrial user to discharge into the publicly owned treatment system, unless specifically authorized in a permit issued by the Approving Authority, any of the following heavy metals in concentrations greater than the amounts specified below.

Metal	Grab Limit (ug/L)	Composite Limit (ug/L)
Arsenic	3000	2000
Cadmium	140	70
Chromium	3000	1000
Copper	75	50
Lead	240	160
Mercury	2	1
Nickel	3000	2000
Selenium	270	160
Zinc	2400	1200
Silver	400	200

In addition, unless specifically authorized in a permit issued by the Approving Authority, no industrial user shall introduce or cause to be introduced into the District's wastewater facilities and the POTW wastewater containing any organic solvent, including but not limited to perchloroethylene, 1,1,1-trichloroethane, trichloroethylene, methylene chloride, trichlorofluoroethane, vinyl chloride, 1,2-dichloroethane, cis-1,2-dichloroethylene, stain/spot removers containing chlorinated and/or aromatic hydrocarbons in excess of the Maximum Contaminant Levels ("MCLs") established in 40 C.F.R. § 141.61.